NOTES:

- 1. MUST BE MIN. 36" AWAY FROM ANY ELECTRICAL PANEL.
- VALVE REQUIRED DOWNSTREAM OF BACKFLOW ASSEMBLY.
- VERTICAL INSTALLATION SHALL BE DESIGNED AND SUBMITTED TO CFPUA EMD FOR APPROVAL.
- 4. LOCATE AS CLOSE TO THE RIGHT-OF-WAY AS POSSIBLE.
- INDOOR INSTALLATIONS MUST BE APPROVED BY CFPUA.
- 6. MUST COMPLETE CFPUA'S BACKFLOW INSTALLATION FORM. CONTACT COMMUNITY COMPLIANCE AT 910-332-6558 OR VISIT WWW.CFPUA.ORG/COMMUNITYCOMPLIANCE AND COMPLETE THE ONLINE FORM.
- 7. ONLY IN-LINE TESTABLE ASSEMBLIES APPROVED BY THE USC FOUNDATION FOR CROSS CONNECTION CONTROL OR ASSE SHALL BE ACCEPTED.

DETAIL:

DOUBLE CHECK VALVE ASSEMBLY

CFPUA DETAIL DATE:

01/01/2025



CAPE FEAR PUBLIC UTILITY AUTHORITY
235 GOVERNMENT CENTER DRIVE
WILMINGTON, NC 28403
OFFICE: (910)332-6560

EM-2

SHEET NO: