


NOT TO SCALE

NOTES:

- 1. UNLESS OTHERWISE SPECIFIED, ALL METAL WET WELL COMPONENTS, HARDWARE, AND FASTENERS, SHALL BE CAST IRON, DUCTILE IRON OR 316 STAINLESS STEEL OR BETTER.
- 2. UNLESS OTHERWISE SPECIFIED, ALL CONCRETE FASTENERS TO BE 316 STAINLESS STEEL WEDGE ANCHORS (TYP).
- 3. ONE PIECE SCHEDULE 40, 316 STAINLESS STEEL GUIDE RAILS. DIAMETER PER MANUFACTURERS RECOMMENDATIONS. TWO PIECE RAILS WITH INTERMEDIATE (MID 1/3) SUPPORT, FOR LENGTHS GREATER THAN 18 FEET. UPPER GUIDE RAIL BRACKET SHALL ALSO BE STAINLESS STEEL.





CAPE FEAR PUBLIC UTILITY AUTHORITY
235 GOVERNMENT CENTER DRIVE
WILMINGTON, NC 28403
OFFICE: (910)332-6560

PS-C3A

SHEET NO:

-