

## SCADA RTU




## FLOW METER



## **NOTES:**

- ENGRAVED PLASTIC FOR NAMEPLATE; BLACK LETTERS ON WHITE BACKGROUND.
- 2. 3/8" ENGRAVED LETTERS EQUIPMENT NAME DESIGNATION AND 1/4" ENGRAVED LETTERS ON ALL OTHER DESIGNATIONS.
- 3. CUSTOMIZE LABELS FOR SPECIFIC EQUIPMENT DESIGNATIONS AND RATINGS FOR THE PROJECT.
- 4. HIGH PERFORMANCE, DOUBLE COATED TAPE WITH ADHESIVE TO ATTACH LABELS. DESIGN BASIS: 3M #06383 OR APPROVED EQUIVALENT.





CAPE FEAR PUBLIC UTILITY AUTHORITY
235 GOVERNMENT CENTER DRIVE
WILMINGTON, NC 28403
OFFICE: (910)332-6560

DETAIL NO: PS-E19

SHEET NO:

3.\TreatmentEngCM\Engineers\2003\_Project Management\2017 Projects\-Standards Update 314817.045\CFPUA Dwg Details\CAD\Electrica\PS-E19 Engraved Nameplate Labels.dwg, 12/5/2024 10:39:29 AM, justin.hanes