- 1. BYPASS AND (3) THREE GATE VALVES REQUIRED FOR 12" AND LARGER FORCE MAINS.
- 2. CONTRACTOR TO INSTALL VALVE AND MANHOLE AT SUFFICIENT DEPTH TO ALLOW FOR ACCESS.
- 3. FORCE MAIN TO BE OFFSET TO KEEP AREA BELOW LID CLEAR.
- 4. ALL BURIED PIPES, VALVES AND FITTING SHALL BE RESTRAINED

DETAIL:

AIR/ VACUUM AND AIR RELEASE
COMBINATION VALVE PLAN

CFPUA DETAIL DATE:
SCALE: NOT TO SCALE

01/01/2025

TreatmentEngCM\Engineers\2003_Project Management\2017 Projects\-Standards Update 314817.045\CFPUA Dwg Details\CAD\S-8 Air-Vacuum And Air Release Combination Valve Plan.dwg, 12/5/2024 8:39:45 AM, justin.hanes



CAPE FEAR PUBLIC UTILITY AUTHORITY
235 GOVERNMENT CENTER DRIVE
WILMINGTON, NC 28403
OFFICE: (910)332-6560

DETAIL NO:

SHEET NO:

-