

- SEWER SERVICES SHALL BE PERPENDICULAR TO MAIN. SEWER SERVICES IN CUL-DE-SACS ARE REQUIRED TO BE PERPENDICULAR, OR MUST ORIGINATE IN END OF LINE MANHOLE AND TERMINATE AT RIGHT-OF-WAY LINE.
- ALL SERVICES CONNECTING INTO DUCTILE IRON MAINS SHALL BE CONSTRUCTED OF DIP, WITH PROTECTIVE LINING.
- CLEANOUTS SHALL BE LOCATED A MINIMUM OF 6 FEET FROM ALL PROPERTY CORNERS.
- FOR PRIVATE 8" SERVICES, MANHOLES ARE REQUIRED FOR CONNECTION TO MAIN.
- A MINIMUM PIPING LENGTH OF 1' 6" SHALL BE USED BETWEEN FITTINGS. 5.
- 6" SERVICES SHALL HAVE A 6" X 4" CONCENTRIC REDUCER INSTALLED ABOVE THE COMBINATION PRIOR TO ENTERING THE CAST IRON BOX.
- NO FLEXIBLE COUPLINGS SHALL BE USED. 7.



S:\TreatmentEngCM\Engineers\2003_