

- 1. FOR PRIVATE 8" SERVICES, MANHOLES ARE REQUIRED FOR CONNECTION TO SYSTEM AND AT THE PROPERTY LINE, WITH REQUIRED EASEMENT.
- 2. ALL SERVICES CONNECTING INTO DUCTILE IRON MAINS SHALL BE CONSTRUCTED OF DIP, WITH PROTECTIVE LINING.
- 3. NO FLEXIBLE COUPLINGS SHALL BE USED.

DETAIL:
SEWER SERVICE CONNECTION MAIN to LATERAL (LESS THAN 8' DEEP)

SCALE: NOT TO SCALE

TreatmentEngCM/Engineers/2003 Project Management/2017 Projects/-Standards Update 314817.045\CFPUA Dwg Details\CAD\S-11 Sewer Service Connection-Typical Main to Lateral (Less than 8' Deep).dwg, 12/11/2024 10:55-42 AM, justin.hanes

CFPUA DETAIL DATE: 01/01/2025



CAPE FEAR PUBLIC UTILITY AUTHORITY
235 GOVERNMENT CENTER DRIVE
WILMINGTON, NC 28403
OFFICE: (910)332-6560

DETAIL NO:

S-11

SHEET NO:

-