

## NOTES:

- FOR FORCE MAINS, CFPUA ACCEPTS THE BELOW NOTED MATERIALS.
- 2" SDR9 1.1.
- 1.2. SDR21
- 1.3. & LARGER - C900 OR DIP
- A GATE VALVE IS REQUIRED AT THE CFPUA FORCE MAIN TAP LOCATION.
- WHEN PRIVATE MAIN IS FROM OPPOSITE SIDE OF NC-DOT ROAD OR CITY STREET, A SECOND VALVE IS REQUIRED 18" INSIDE PUBLIC R/W.
- IF TAPPING VALVE IS LESS THAN 5-FEET FROM R/W THEN SECOND VALVE AT R/W IS NOT REQUIRED.

