


## **NOTES:**

- 1. CONCRETE SHALL NOT CONTACT BOLTS OR ENDS OF MECHANICAL JOINT FITTINGS.
- 2. PIPE & FITTING TO BE WRAPPED IN 10 MIL. PLASTIC OR 15 LB. ASPHALTIC FELT PRIOR TO THRUST BLOCK BEING POURED.
- 3. TEST PRESSURE SHALL NOT BE APPLIED FOR A MINIMUM OF 7 DAYS AFTER THRUST BLOCK PLACEMENT.
- 4. BRANCH SHALL NOT EQUAL RUN DIAMETER UNLESS APPROVED BY CFPUA ENGINEERING.





CAPE FEAR PUBLIC UTILITY AUTHORITY
235 GOVERNMENT CENTER DRIVE
WILMINGTON, NC 28403
OFFICE: (910)332-6560

WS-9

SHEET NO:

TreatmentEngCM\Engineers\2003\_Project Management\2017 Projects\-Standards Update 314817.045\(CFPUA Dwg Details\CAD\WS-9 Tapping Sleeve and Valve Assembly 4-24 dwg, 12/2024 3:11:04 PM, justin.hanes