


SIZE	90 B	BENDS B	45 E	BENDS B	22-1/2 A	BENDS B	TEES/	PLUGS B	45 VERT. BENDS
3" 4"	8" 8"	6" 9"	5" 5"	6" 8"	3" 3"	7" 11"	6" 6"	8" 9"	27" 28"
6"	14" 16"	11" 16"	9"	9" 12"	8" 10"	8" 13"	12" 14"	9" 13"	36" 42"
10"	18"	22"	15"	14"	14"	16"	18"	15"	50"
12"	20" 26"	28" 29"	18"	17" 19"	16" 18"	16" 18"	22" 26"	18" 20"	62" 72"
16" 18"	33" 40"	29" 30"	25" 28"	21" 24"	20" 22"	21" 23"	32" 36"	21" 24"	83" 88"

NOTES:

- THRUST BLOCKING IS NOT PERMITTED EXCEPT IN SPECIAL INSTALLATIONS WHERE DESIGNED BY ENGINEER AND APPROVED BY CFPUA.
- 2. ALLOW 7-DAY MINIMUM CONCRETE CURE TIME BEFORE PLACING LOAD ON THRUST BLOCK
- 3. BASED ON 150 PSI TEST PRESSURE AND 2,000 PSF SOIL BEARING CAPACITY.
- 4. ALL BEARING SURFACES TO BE CARRIED TO UNDISTURBED GROUND.
- 5. PIPE & FITTINGS TO BE WRAPPED IN 10 MIL PLASTIC PRIOR TO THRUST BLOCK BEING POURED.





CAPE FEAR PUBLIC UTILITY AUTHORITY
235 GOVERNMENT CENTER DRIVE
WILMINGTON, NC 28403
OFFICE: (910)332-6560

DETAIL NO:

SHEET NO: