


NOTES:

- PROVIDE TOTAL LENGTH OF RESTRAINED JOINTS UPSTREAM AS REQUIRED FOR MAIN DIAMETER AT 150 psi TEST PRESSURE. WHEN UPSTREAM BENDS ARE WITHIN THE DEAD LENGTH, ADD TOTAL BEND RESTRAINT FOR EACH BEND TO DEAD—IN LENGTH.
- 2. IF MAIN IS LARGER THAN 2", END WITH A VALVE SIZED FOR THE MAIN, THREADED CAP SIZED ON VALVE FOR THE 2" BLOW-OFF.





CAPE FEAR PUBLIC UTILITY AUTHORITY
235 GOVERNMENT CENTER DRIVE
WILMINGTON, NC 28403
OFFICE: (910)332-6560

W-7

SHEET NO:

S.\TeatmentEngCM\Engineers\2003_Project Management\2017 Projects\-Standards Update 314817.045\CFPUA Dwg Details\CAD\W-7 2 Inch Blow-Off.dwg, 12/2\2024 12:58:15 PM, justin.hanes