

- METER BOXES SUBJECT TO TRAFFIC SHALL CONFORM TO ASTM A48, CLASS 30B AND AASHTO H20 LOAD RATING STANDARDS.
- 3" CLEAN FILL REQUIRED ALL AROUND 1" POLY SERVICE LINE.
- METER BOXES SHALL BE LOCATED MINIMUM 5-FEET FROM THE PROPERTY CORNER.
- 6. ASSEMBLY TO BE CENTERED IN THE METER BOX.
- 7. MATERIALS PER CFPUA MSM.
- 8. USE OF THIS DETAIL IS LIMITED TO RESIDENTIAL & WATER METER APPLICATIONS ONLY.
- 9. EIGHT (8) SERVICES MAXIMUM PER GANG METER ASSEMBLY.
- 10. USE OF THIS DETAIL REQUIRES CFPUA APPROVAL.
- 11. PLASTIC PIPE STIFFENERS SHALL BE USED.



S:XTreatmentEngCM\Engineers\2003_Project Management\2017 Projects\-Standards Update 314817.045\CFPUA Dwg Details\CAD\W-15 Single Domestic Water Service Gang Meter.dwg, 12/11/2024 1:46:57 PM,